

Village of Bolivar

2020 Consumer Confidence Report

Is my water safe?

We are pleased to present this year's Annual Water Quality Report (Consumer Confidence Report) as required by the Safe Drinking Water Act (SDWA). This report is designed to provide details about where your water comes from, what it contains, and how it compares to standards set by regulatory agencies. This report is a snapshot of last year's water quality. We are committed to providing you with information because informed customers are our best allies.

Do I need to take special precautions?

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. EPA/Centers for Disease Control (CDC) guidelines on appropriate means to lessen the risk of infection by *Cryptosporidium* and other microbial contaminants are available from the Safe Water Drinking Hotline (800-426-4791).

Where does my water come from?

The Village of Bolivar operates three water wells located at Waterwork's Park. The Village of Bolivar has a current, unconditioned license to operate our water system.

Source water assessment and its availability

The Village of Bolivar has completed a source water protection plan. The Village of Bolivar's source of drinking water has a high susceptibility to contamination due to : lack of protective layer of clay, shale or other relatively impermeable material overlying the aquifer, shallow depth to water (30 -50 feet below ground surface), and presence of potential contaminant sources in the protection area. Copies of the source water assessment report prepared for the Village of Bolivar are available by contacting the Village Administrator at 330-874-3717; ext. 2.

Why are there contaminants in my drinking water?

Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the Environmental Protection Agency's (EPA) Safe Drinking Water Hotline (800-426-4791).

The sources of drinking water (both tap water and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs, and wells. As water travels over the surface of the land or through the ground, it dissolves naturally occurring minerals and, in some cases, radioactive material, and can pick up substances resulting from the presence of animals or from human activity: microbial contaminants, such as viruses and bacteria, that may come from sewage treatment plants, septic systems, agricultural livestock operations, and wildlife; inorganic contaminants, such as salts and metals, which can be naturally occurring or result from urban stormwater runoff, industrial, or domestic wastewater discharges, oil and gas production, mining, or

farming; pesticides and herbicides, which may come from a variety of sources such as agriculture, urban stormwater runoff, and residential uses; organic Chemical Contaminants, including synthetic and volatile organic chemicals, which are by-products of industrial processes and petroleum production, and can also come from gas stations, urban stormwater runoff, and septic systems; and radioactive contaminants, which can be naturally occurring or be the result of oil and gas production and mining activities. In order to ensure that tap water is safe to drink, EPA prescribes regulations that limit the amount of certain contaminants in water provided by public water systems. Food and Drug Administration (FDA) regulations establish limits for contaminants in bottled water which must provide the same protection for public health.

How can I get involved?

Public participation and comments are encouraged at regular Village of Bolivar Council meetings which are held the first Monday of each month at 7:00PM.; Village Hall, 109 Canal Street NE, Bolivar, OH 44612. Please contact the Village Administrator at 330-874-3717; ext. 2 if you would like more information.

Additional Information for Lead

If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. Bolivar Village PWS is responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at <http://www.epa.gov/safewater/lead>.

Water Quality Data Table

In order to ensure that tap water is safe to drink, EPA prescribes regulations which limit the amount of contaminants in water provided by public water systems. The table below lists all of the drinking water contaminants that we detected during the calendar year of this report. Although many more contaminants were tested, only those substances listed below were found in your water. All sources of drinking water contain some naturally occurring contaminants. At low levels, these substances are generally not harmful in our drinking water. Removing all contaminants would be extremely expensive, and in most cases, would not provide increased protection of public health. A few naturally occurring minerals may actually improve the taste of drinking water and have nutritional value at low levels. Unless otherwise noted, the data presented in this table is from testing done in the calendar year of the report. The EPA or the State requires us to monitor for certain contaminants less than once per year because the concentrations of these contaminants do not vary significantly from year to year, or the system is not considered vulnerable to this type of contamination. As such, some of our data, though representative, may be more than one year old. In this table you will find terms and abbreviations that might not be familiar to you. To help you better understand these terms, we have provided the definitions below the table.

<u>Contaminants</u>	<u>MCLG</u> or <u>MRDLG</u>	<u>MCL,</u> <u>TT, or</u> <u>MRDL</u>	<u>Your</u> <u>Water</u>	<u>Range</u>		<u>Sample</u> <u>Date</u>	<u>Violation</u>	<u>Typical Source</u>
				<u>Low</u>	<u>High</u>			
Inorganic Contaminants								
Nitrate [measured as Nitrogen] PPM	10	10	0.494	N/A	N/A	2020	NO	Runoff from fertilizer use; Leaching from septic tanks, Sewage; Erosion of Natural Deposits
Total Trihalomethanes PPB	N/A	80	11.9 PPB	6.87 PPB	15.5 PB	2020	NO	Byproduct of disinfection
Gross Alpha pCi/L	0	15	0.522	N/A	N/A	2019	NO	Erosion of Natural Deposits
Selenium PPB	50	50	3.99	N/A	N/A	2019	NO	Discharge prom petroleum and metal refineries; erosion of natural deposits; discharge from mines
Total Chlorine PPM	4 ppm MRDLG	4 ppm MRDL	.79	.59	1.19	2020	No	Added to the water for disinfection
Chromium PPB	100	100	7.96	N/A	N/A	2019	No	Discharge from steel and pulp mills, erosion of natural deposits
Fluoride PPM	4	4	0.3	N/A	N/A	2019	No	Erosion of natural deposits; Water additive which promotes strong health. Discharge from fertilizer and aluminum factories.
Barium PPM	2	2	.148 PPM	N/A	N/A	2019	No	Discharge from drilling wastes & metal refineries, erosion of natural deposits

Contaminants (units)	Action Level (AL)	Individual Results over the AL	90% of test levels were less than	Violation	Year Sampled	Typical source of Contaminants
Lead (ppb)	15 ppb	0	0 ppb	None	2018	Corrosion of household plumbing systems, erosions of natural deposits; leaching from wood present.
<p style="text-align: center;">__0__ out of __10__ samples were found to have lead levels in excess of the lead action level of 15 ppb.</p>						
Copper (ppm)	1.3 ppm	0	0.219 ppm	None	2018	Corrosion of household plumbing systems, erosions of natural deposits; leaching from wood present.
<p style="text-align: center;">__0__ out of __10__ samples were found to have copper levels in excess of the copper action level of 1.3 ppm.</p>						

Term	Definition
Ppm	ppm: parts per million, or milligrams per liter (mg/L)
Ppb	ppb: parts per billion, or micrograms per liter (µg/L)
NA	NA: not applicable
ND	ND: Not detected
NR	NR: Monitoring not required, but recommended.
pCi/L	A common measure of radioactivity

Important Drinking Water Definitions	
Term	Definition
MCLG	MCLG: Maximum Contaminant Level Goal: The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.
MCL	MCL: Maximum Contaminant Level: The highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.
TT	TT: Treatment Technique: A required process intended to reduce the level of a contaminant in drinking water.
AL	AL: Action Level: The concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a water system must follow.
Variances and Exemptions	Variances and Exemptions: State or EPA permission not to meet an MCL or a treatment technique under certain conditions.
MRDLG	MRDLG: Maximum residual disinfection level goal. The level of a drinking water disinfectant below which there is no known or expected risk to health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants.
MRDL	MRDL: Maximum residual disinfectant level. The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.
MNR	MNR: Monitored Not Regulated
MPL	MPL: State Assigned Maximum Permissible Level

For more information please contact:

Contact Name: Chuck Williams Water Operator

Address:

Village of Bolivar

PO Box 117

109 Canal St NE

Bolivar, OH 44612

Phone: (330) 874-3717; ext. 2

Fax: (330)874-3713

E-Mail: cdwilliams178@gmail.com

Website: www.villageofbolivar.com